

Test-Unit

Type: **Dynameco PSDY06**

Only for connection to fire extinguishing systems of Co. EGON HARIG GmbH

<u>Length:</u>	approx. 60 mm
<u>Diameter:</u>	approx. 10 mm
<u>Internal resistance:</u>	1.5 Ω / 5 W (simulates the igniter)
<u>Plug contacts:</u>	1 mm contact pins
<u>P/N:</u>	80 374

no
reversed
polarity by
bipolar
execution



plugged
into a
Dynameco
Connection
Cable



Purpose of use:

Test-Units Dynameco PSDY06 simulate the electrical behavior of AEROSOL Fire Extinguishing Generators of types: Dynameco ...- E0... during functional checks of Fire Detection and Extinguishing Systems. They indicate the functions of the igniters, while the LEDs blink in time with the ignition pulses. The check plans for each Fire Detection and Extinguishing System must be considered!